

2003 IFC reference #'s

Occupancy Identification

- Street Address on side A / visible **505.1**
- Key Box on building N/A **506.1**

Fire Extinguishers

- One 2-A: 10-BC fire extinguisher per 75 feet of travel. **906.2**
- Extinguisher mounted to be visible and no higher than 5 feet above floor. **906.9**
- Extinguishers serviced annually (last service date is shown on tag). **901.6.1**
- Restaurants - One **Type K** extinguisher required in kitchen. **904.11.5**
- Hood and Duct Systems serviced/tagged every six months. **904.11.6.4**
- Hoods, fans, and ducts cleaned regularly and tagged. **904.11.6.3**

Sprinklers

- 18-inch clearance is required below sprinkler heads. **315.2.1**
- No decoration or attachments are allowed on sprinkler piping/heads. **315.2.1**
- Sprinkler Systems serviced/tagged every 12 months. **901.6.1**

Exiting - Doors, Signs and Aisles

- Fire doors are maintained self-closing and latching. **703.2**
- Exit doors, aisles, corridors and stairs are free of obstructions and storage. **1003.6**
- Exit signs are illuminated and battery backup functions. **1011.5**
- Emergency lights operate. **1006.3**

Electrical Safety

- Power taps (outlet strips) are UL listed. **605.4.1**
- Power taps are plugged directly into permanent outlets. **605.4.2**
- Extension cords are used only with portable appliances. **605.5.1**
- Extension cords are plugged directly into permanent outlets or power taps. **605.5.1**
- Extension cords not run through walls, ceilings, Floors, or doorways, or under rugs. **605.5**
- Maintain 30-inch clearance in front of all electrical panels. **605.3**
- Panels and electrical boxes are covered - no exposed wiring. **605.1**
- Electrical rooms, switchboards and panelboards must be clearly & durably marked. **605.3.1**

Fire Resistive Construction

- Fire Resistive Construction must be intact. **703.1**

Housekeeping

- Storage is orderly. **315.2**
- Combustible wastes not allowed to accumulate. **304.1**
- No** storage of combustible materials in electrical or boiler rooms. **315.2.3**
- Combustible storage in concealed spaces must have 1-hour rating. **315.2.4**